


No. 2009-BO-0040



Safety Certificate

SEOJIN INSTECH CO., LTD.

14, Dunchon-daero 457beon-gil, Jungwon-gu, Seongnam-si, Gyeonggi-do, Korea

The following product produced by the above company has been authorized for the use of the Mark  as the product has satisfied the safety and health standards stipulated in the article 34 of Industrial Safety and Health Law.

PRODUCT

Displacement Type Level Switch

TYPE · MODEL/CAPACITY · GRADE/CERTIFICATION No

TYPE · MODEL
SMC

CERTIFICATION No.
09-AV2B0-0081

CAPACITY · GRADE

Ex d IIC T6 IP65
AC 125V, 15A/ 250V, 10A,
Tamb: -10°C ~60°C

SAFETY CERTIFICATION STANDARDS

Notification No. 2008-76 of the Ministry of Employment and Labor

CERTIFICATION CONDITION

It is only for the product manufactured in "SEOJIN INSTECH CO., LTD., 14, Dunchon-daero 457beon-gil, Jungwon-gu, Seongnam-si, Gyeonggi-do, Korea"

DATE : Dec. 20, 2017

Jul. 22, 2009(Original issue)

Signature Lee, Young Soon

President of Korea Occupational Safety and Health Agency