


No. 2011-BO-0368-1



Safety Certificate

SEOJIN INSTECH CO., LTD.

14, Dunchon-daero 457beon-gil, Jungwon-gu, Seongnam-si, Gyeonggi-do, Korea

The following product produced by the above company has been authorized for the use of the Mark  as the product has satisfied the safety and health standards stipulated in the article 34 of Industrial Safety and Health Law.

PRODUCT

Local Indicator

TYPE · MODEL/CAPACITY · GRADE/CERTIFICATION No

TYPE · MODEL

SAI-100EX

CERTIFICATION No.

11-AV2BO-0368

CAPACITY · GRADE

Ex d IIC T6 IP65
DC 24 V, 4~20 mA, Tamb: -20°C ~60°C

SAFETY CERTIFICATION STANDARDS

Notification No. 2010-36 of the Ministry of Employment and Labor

CERTIFICATION CONDITION

- It is only for the product manufactured in "SEOJIN INSTECH CO., LTD., 14, Dunchon-daero 457beon-gil, Jungwon-gu, Seongnam-si, Gyeonggi-do, Korea"
- The overpressure test for every products shall be conducted with pressure of 2 300kPa for main body and 2 500kPa for terminal box

DATE : DEC. 20. 2017

OCT. 06. 2011(Original issue)

Signature

Lee, Young Soon

President of Korea Occupational Safety and Health Agency