


No. 2009-BO-0041



# Safety Certificate

SEOJIN INSTECH CO., LTD.

14, Dunchon-daero 457beon-gil, Jungwon-gu, Seongnam-si, Gyeonggi-do, Korea

The following product produced by the above company has been authorized for the use of the Mark  as the product has satisfied the safety and health standards stipulated in the article 34 of Industrial Safety and Health Law.

## PRODUCT

Level Switch

### TYPE · MODEL/CAPACITY · GRADE/CERTIFICATION No

TYPE · MODEL

SMGS

CERTIFICATION No.

09-AV2B0-0082

CAPACITY · GRADE

Ex d IIC T6 IP65  
DC 125 V, 0.5 A / AC 250 V, 5 A  
-10 °C ≤ Tamb ≤ +60 °C

## SAFETY CERTIFICATION STANDARDS

Notification No.2008-76 of the Ministry of Employment and Labor

## CERTIFICATION CONDITION

It is only for the product manufactured in "SEOJIN INSTECH CO., LTD., 14, Dunchon-daero 457beon-gil, Jungwon-gu, Seongnam-si, Gyeonggi-do, Korea"

DATE : Oct. 16, 2018

Jul. 24, 2009(Original issue)

Signature

President of Korea Occupational Safety and Health Agency