No. 2009-B0-0007



## Safety Certificate

SEOJIN INSTECH CO., LTD.

14, Dunchon-daero 457beon-gil, Jungwon-gu, Seongnam-si, Gyeonggi-do, Korea

The following product produced by the above company has been authorized for the use of the Mark [s as the product has satisfied the safety and health standards stipulated in the article 34 of Industrial Safety and Health Law.

## **PRODUCT**

Float Level Transmitter

TYPE - MODEL/CAPACITY - GRADE/CERTIFICATION NO

TYPE · MODEL

CERTIFICATION No.

ST-600

09-AV2B0-0007

**CAPACITY - GRADE** 

Ex d IIC T6 IP65 DC 24 V, 25 mA, 0.75 kW

-20 °C  $\leq$  Tamb  $\leq$  +60 °C, -20 °C  $\leq$  Tfluid  $\leq$  +60 °C

## SAFETY CERTIFICATION STANDARDS

Notification No.2018-76 of the Ministry of Employment and Labor

## **CERTIFICATION CONDITION**

It is only for the product manufactured in "SEOJIN INSTECH CO., LTD., 14, Dunchon-daero 457beon-gil, Jungwon-gu, Seongnam-si, Gyeonggi-do, Korea"

DATE: Oct. 16, 2018

May. 21, 2009 (Original issue)

Signature

De York Park

President of Korea Occupational Safety and Health Agency